

.

From: Customer Request <custreq@facil.umass.edu>
Sent: Wednesday, May 23, 2012 8:05 AM
To: servdesk@facil.umass.edu
Cc: Hanchett, James (DPH)
Subject: FW: WReq Entry for Morrill I on Wednesday, May 23, 2012 - 08:03

Please create a service call work order for the zone maintenance.Thanks

-----Original Message-----

From: webadmin@oit.umass.edu [<mailto:webadmin@oit.umass.edu>]
Sent: Wednesday, May 23, 2012 8:03 AM
To: custreq@facil.umass.edu
Subject: WReq Entry for Morrill I on Wednesday, May 23, 2012 - 08:03

The results of this submission may be viewed at:
<https://www.umass.edu/af-forms/node/9/submission/7311>

Submitted on Wednesday, May 23, 2012 - 08:03 by hanchett

--Requester Information--

Netid: hanchett
Request Date: Wednesday, May 23, 2012 - 08:03
First & Last Name: Jim Hanchett
Department: Mass Public Health
Mailing Address:
Room N251 Morrill I
637 North Pleasant St.
Amherst, MA 01003
Email: james.hanchett@state.ma.us
Phone Number: 5452607
Fax: 5452608

--Work Request Information--

Building Requiring Work: Morrill I
Room Number/Location: N236
Describe Work Requested: Could you have the steam heat turned off
in Morrill I. It leaks past valves and heats up our office.

=====

Morrill I N236, Could you have the steam heat turned off in Morrill I. It leaks past valves and heats up our office., Jim Hanchett, Phone: 5452607,
Fax: 5452608

